

Figure: 30 TAC §317.4(1)(2)(H)

Air Scour	3 - 5 scfm/ft <sup>2</sup>
Water Scour	0.5 - 2 gpm/ft <sup>2</sup>
Backwash Water	6 - 8 gpm/ft <sup>2</sup>