

Figure: 30 TAC §317.5(c)(1)

Type of Sludge	Cubic Feet Per Pound BOD₅ Per day Unheated Digester	Cubic Feet Per Pound BOD₅ Per day Heated Digester
Sludge from primary clarifiers	20.5	14.5
Sludge from primary clarifiers, including Imhoff tanks, plus sludge from clarifiers following trickling filters; sludge from chemical precipitation units, either alone or with sludge from biological treatment unit	26.5	19.0
Sludge from primary clarifiers with waste activated sludge or contact stabilization sludge; sludge from secondary clarifiers	44.0	29.5