

Figure: 30 TAC §317.2(c)(5)(B)

Pipe Diameter (inches)	Maximum Manhole Spacing (feet)
6-15	500
18-30	800
36-48	1,000
54 or larger	2,000