

Figure: 30 TAC §317.4(a)

| | | Daily Wastewater Flow - Gallons | Wastewater Strength |
|----------------------------|-------------------------|--|--------------------------------|
| Source | Remarks | Per Person | mg/L BOD₅ |
| Municipality | Residential | 100 | 200 |
| Subdivision | Residential | 100 | 200 |
| Trailer Park (Transient) | 2 ½ persons per trailer | 50 | 300 |
| Mobile Home Park | 3 persons per trailer | 75 | 300 |
| School with Cafeteria | With Showers | 20 | 300 |
| | Without Showers | 15 | 300 |
| Recreational Parks | Overnight user | 30 | 200 |
| | Day user | 5 | 100 |
| Office Building or Factory | | 20 | 300 |
| Motel | | 50 | 300 |
| Restaurant | Per Meal | 5 | 1000 |
| Hospital | Per Bed | 200 | 300 |
| Nursing Home | Per Bed | 100 | 300 |