

Figure 3: 30 TAC §217.164(e)(2)(I)

Table F.11. - Values for Use in Determining Sludge Storage Requirements

Underflow (gpd/sf)	200	250	300	350	400
RSSS maximum (mg/l)	12,813	11,743	10,935	10,295	9,771
Blanket concentration (mg/l)	7,816	7,163	6,670	6,280	5,961
Blanket (lb/cf)	0.488	0.447	0.416	0.392	0.372