

Figure: 30 TAC §217.164(e)

Equation F.8.

$$A_c = \frac{1,000,000 Q_p}{OR_p}$$

Where:

A_c = area of the clarifier(s), square feet

Q_p = peak flow, million gallons per day

OR_p = weir overflow rate (gallons per day per square foot) from Table F.9. in Figure 1: 30 TAC §217.164(e)(2)(I)