

Figure: 30 TAC §217.211(g)(2)

Equation H.5.

$$C_o = C^* + (C_i - C^*) \exp^{-\frac{Ka}{0.0365Q}}$$

Where:

$C_i$  = influent five-day biochemical oxygen demand (BOD<sub>5</sub>) concentration, milligram per liter (mg/l)

$C_o$  = target effluent BOD<sub>5</sub> concentration, mg/l

$C^*$  = wetland background limit, mg/l

(for total suspended solids (TSS)  $C^* = 7.8 + 0.063C_i$ )

(for BOD<sub>5</sub>,  $C^* = 3.5 + 0.053C_i$ )

$K$  = first-order areal rate constant:

(180 meters per year (m/yr) @ 20° C for BOD<sub>5</sub>)

(3,000 m/yr @ 20° C for TSS)

$a$  = is required wetland area, hectare (active treatment area, not including dike, buffers, etc.)

$Q$  = design flow in cubic meters per day