

Figure: 30 TAC §217.243(e)

Table J.1. Sludge Processing Minimum Pipe Diameter

Pipe	Diameter
Sludge drainpipe	4.0 inches
Pipe in a sludge digester	4.0 inches
Suction pump pipe	4.0 inches
Discharge pipe	4.0 inches
Gravity withdrawal pipes associated with an anaerobic digester or gravity thickener	6.0 inches