

Figure: 30 TAC §217.250(e)(2)(A)(ii)

**Table J.3. - Surface Area Requirements for Sludge Drying Beds**

<b>Stabilization Process</b>	<b>Pounds of Digested Dry Solids <i>per square foot per year</i></b>
Anaerobic Digestion	20.0
Aerobic Digestion	15.0