

Figure: 30 TAC §217.250(e)(4)(A)

Table J.4. - Filtration Rates

Type of Treatment	Pounds of Dry Solids <i>per square foot per hour</i> <i>(minimum-maximum)</i>
Primary	4-6
Primary and Trickling Filter	3-5
Primary and Activated Sludge	3-4