

Figure: 30 TAC §217.272(b)

**Table K.1. - Minimum Design Chlorine Concentration Needed for Disinfection**

Type of Effluent	Chlorine Concentration <i>milligrams per liter (mg/l)</i>
Primary	15
Fixed Film	10
Activated Sludge	8
Tertiary Filtration Effluent	6
Nitrified Effluent	6