

Figure: 16 TAC §13.93(g)

§13.93 SIGNS/LETTERING

Requirements	Automatic Dispenser/Refueling Area⁵	Fueling Connection Receptacle CNG Fueled Vehicle	Engine Compartment of CNG Fueled Vehicle	Emergency Shutdown Devices	Compression Area⁵
1. Signs with Red Letters at Least 2 Inches High, on White Background - NO SMOKING ¹	■				■
2. Sign with Red Letters at Least 4 Inches High, on White Background: WARNING-FLAMMABLE GAS; Black letters: NO TRESPASSING					■
3. Letters at Least 2 Inches High: NATURAL GAS	■ ⁷				■
4. CNG FUELED VEHICLE		■ ²	■		
5. System Working Pressure _____		■ ²	■		
6. Name of Licensee and License Number			■		
7. Cylinder Retest Date(s) or Expiration Date(s) ³		■ ²	■		
8. Total Cylinder Water Volume in Gallons			■		
9. Sign with White Letters at Least 2 Inches High on Red Background: CNG EMERGENCY VALVE; PUSH				■ ⁴	
10. Letters at Least 4 Inches High: Name of Licensee Operating Installation	■ ⁶				■ ⁶

NOTES TO §13.93, TABLE 1

1. *Location of sign shall be determined by on-site conditions, but shall be visible from each point of transfer.*
2. *On durable label, readily visible. Information in items 4, 5, 6, 7, 8 may be combined on one label.*
3. *When applicable.*
4. *Devices shall be distinctly marked for easy recognition with permanently affixed, legible sign.*
5. *Does not apply to residential/refueling facility.*
6. *One sign may be installed at either location.*
7. *On each operating side of dispenser.*