

Figure: 16 TAC §13.303

NFPA 55 Sections with Additional Requirements or Not Adopted		
Affected NFPA 55 Section	Specific Action	Commission Rule(s) to be Followed or Other Comments
4.1	additional requirement	See Commission rule §13.25, Filings required for stationary CNG installations
4.7	additional requirement	See Commission rule §13.70, Examination and exempt registration requirements and renewals
4.10	additional requirement	See Commission rule §13.93, System protection requirements
4.11	additional requirement	See Commission rule §13.93, System protection requirements
7.1.6.1	additional requirement	See Commission rule §13.40, Manufacturer's nameplates and markings on ASME containers
7.1.8.3	additional requirement	See Commission rule §13.93, System protection requirements
7.1.9	additional requirement	See Commission rule §13.93, System protection requirements
7.1.12	additional requirement	See Commission rule §13.61, License categories, container manufacturer registration, fees, and application for licenses, manufacturer registrations and renewals
7.1.14	additional requirement	See Commission rule §13.38, Removal from CNG service
7.1.15	additional requirement	See Commission rule §13.38, Removal from CNG service
Chapter 8	not adopted	NFPA 55 Chapter 8 does not apply to CNG installations
Chapter 9	not adopted	NFPA 55 Chapter 9 does not apply to CNG installations
Chapter 10	not adopted	NFPA 55 Chapter 10 does not apply to CNG installations
Chapter 11	not adopted	NFPA 55 Chapter 11 does not apply to CNG installations
Chapter 12	not adopted	NFPA 55 Chapter 12 does not apply to CNG installations
Chapter 13	not adopted	NFPA 55 Chapter 13 does not apply to CNG installations
Chapter 14	not adopted	NFPA 55 Chapter 14 does not apply to CNG installations
Chapter 15	not adopted	NFPA 55 Chapter 15 does not apply to CNG installations