

Figure: 16 TAC §14.2101(f)

§14.2101. Uniform Protection Requirements
Table 1

Requirements for Signs	LNG Vehicle Dispenser/Refueling Area	Emergency Shutdown Devices	LNG Loading or Unloading Area
Red capital letters at least 2" high on white background: NO SMOKING OR OPEN FLAMES	*		*
Red capital letters at least 4" high on white background: FLAMMABLE GAS			*
Black capital letters at least 4" high on white background: NO TRESPASSING AUTHORIZED PERSONNEL ONLY			*
Capital letters at least 2" high FLAMMABLE GAS	*		*
White capital letters at least 2" high on red background: EMERGENCY SHUTDOWN		*	
White capital letters at least 2" high on red background: EMERGENCY PUMP/COMPRESSOR SHUTDOWN		*	
Letters at least 2" high: PRESSURE RELIEF DEVICE SET AT _____			*
Letters at least 4" high: Name of Licensee	*		*