

Figure: 16 TAC §14.2903

NFPA 59A Sections with Additional Requirements or Not Adopted		
Affected NFPA 59A Section	Specific Action	Commission Rule(s) to be Followed or Other Comments
9.4.2.3	additional requirement	See Commission rule §14.2416, Installation of Valves
9.4.2.4	additional requirement	See Commission rule §14.2416, Installation of Valves
11.6	additional requirement	See Commission rule §14.2119, Transport Vehicle Loading and Unloading Facilities and Procedures
11.8	additional requirement	See Commission rule §14.2122, Pumps and Compressors Used for LNG and Refrigerants and §14.2125, Hoses and Arms
12.7	additional requirement	See Commission rule §14.2131, Fire Protection
12.9.3	additional requirement	See Commission rule §14.2101, System Protection Requirements
13.2.3	additional requirement	See Commission rule §14.2101, System Protection Requirements
13.18.3.1	additional requirement	See Commission rule §14.2131, Fire Protection
14.9	additional requirement	See Commission rule §14.2019, Examination Requirements and Renewals