

Figure: 30 TAC §115.175(b)

<b>True Vapor Pressure</b>	<b>Storage Capacity in gallons (gal)</b>	<b>Control Requirements</b>
≥ 1.5 psia and < 11 psia	> 1,000 gal and ≤ 40,000 gal	Submerged fill pipe or closed vent system routed to control device
≥ 1.5 psia and < 11 psia	> 40,000 gal	Internal floating roof or external floating roof with primary seal (any type) and secondary seal or closed vent system routed to control device
≥ 11 psia	> 1,000 gal and ≤ 40,000 gal	Submerged fill pipe or closed vent system routed to control device
≥ 11 psia	> 40,000 gal	Submerged fill pipe and closed vent system routed to control device