

Figure: 30 TAC §117.1120(c)

$$\text{System Cap} = \sum_{i=1}^N (H_i \times R_i)$$

Where:

System Cap = NO<sub>x</sub> emission cap for an electric power generating system in pounds per day on a rolling 30-day average basis;

i = each EGF in the electric power generating system;

N = the total number of EGFs in the system cap;

H<sub>i</sub> = the average of the daily heat input for each EGF in the system cap, in million British thermal units per day, as certified to the executive director, for any 30-day period in 2019, 2020, 2021, 2022, or 2023; the same 30-day period must be used for all EGFs in the emission cap; and

R<sub>i</sub> = the applicable emission specification in §117.1105 of this title for each EGF.