

Figure: 30 TAC §290.112(b)(1)

Step 1 TOC Removal Requirements

Source-water TOC (mg/L)	Source-water alkalinity (mg/L as CaCO ₃) Less than or Equal to...		
	0 - 60	≥60 - 120	≥120
≥ 2.0 - 4.0	35.0% Removal	25.0% Removal	15.0% Removal
≥ 4.0 - 8.0	45.0% Removal	35.0% Removal	25.0% Removal
≥ 8.0	50.0% Removal	40.0% Removal	30.0% Removal